




DO NOT SCALE




RUNG LADDER EXTENSION STANCHION
SCALE 1:5




HANDGRIP DETAIL
1 DETAIL
SCALE 1:2




A VIEW
SCALE 1:2




B VIEW
SCALE 1:2



2 DETAIL
SCALE 1:2



3 DETAIL
SCALE 1:2



C VIEW
SCALE 1:5

NOTES:


1. REFER DRG. BW-SD-S021 FOR RUNG LADDER DETAILS. DIMENSIONS ON THIS DRAWING TAKE PRECEDENCE OVER BW-SD-S021.
2. ALL DETAILS TO COMPLY WITH AS1657.
3. ALL MILD STEEL WORK TO BE HOT DIPPED GALVANISED AFTER FABRICATION.
4. ALL ANCHORS 100mm MIN. EMBEDMENT, 65mm MIN. EDGE DISTANCE.
5. CONTRACTOR TO SUBMIT SHOP DRAWINGS FOR REVIEW PRIOR TO FABRICATION.

MEMBER SCHEDULE			
DESCRIPTION	No. REQ'D	MATERIAL - MILD STEEL (HDG)	MATERIAL - STAINLESS STEEL (G316)
EXTENSION STILE SUPPORT ANGLE	4	90 x 10 EA x 100 LONG	90 x 10 EA x 100 LONG
LOCATING PLATE	4	6 PLATE x 12 WIDE x 20 LONG	6 PLATE x 12 WIDE x 20 LONG
LOCKING PIN	2	DN12 x 70 LONG	DN12 x 70 LONG
HAND GRIP	2	DN12 ROD	DN12 ROD
STANCHION	2	42.4 x 2.0 CHS	42.2 OD x 2.77 THICK TUBE
ANCHOR	-	M12 801 SERIES CHEMSETS (HDG)	M12 801 SERIES CHEMSETS (G316 SS)

STANDARD DRAWING

REFERENCES	
DRAWING	TITLE

REVISIONS							
No.	REVISION DESCRIPTION	OPS	OPS DATE	DRAWN	CHECKED	APPROVED	DATE
0	ISSUED FOR USE (BWA-SD-S022)	-	-	-	-	PT*	11.09.14



DRG No. BW-SD-S022
DRAWING DISCIPLINE: GENERAL
SHEET NO. 1 of 1

BARWON WATER - STANDARD DRAWING VERTICAL RUNG LADDER EXTENSION STANCHION			F.C.	FILE NO.
DRAWN A. PRIMUS JULY '12	DESIGNED S. FOX JULY '12	APPROVED P. THOMAS* 11.09.14	SCALE: PLAN SECTION HORIZ. AS SHOWN VERT. AS SHOWN Scale for A1 sheet	A1